

MARCH
MIDWAY AIRPORT (MIDNIGHT TO MIDNIGHT)
HEATING AND COOLING CALENDAR DEGREE DAYS

Date	Temperature F.			Daily Heating Degree Days (HDD)		
	Max	Min	Mean	Actual HDD Per Day 2014	5600 HDD Per Day	Variation to 5600 HDD Colder (Warmer)
March 1, 2014	32	12	22	43	30	13
March 2, 2014	16	5	11	54	30	24
March 3, 2014	20	1	11	54	30	24
March 4, 2014	27	12	20	45	29	16
March 5, 2014	24	20	22	43	29	14
March 6, 2014	32	16	24	41	29	12
March 7, 2014	46	20	33	32	29	3
March 8, 2014	39	23	31	34	29	5
March 9, 2014	42	21	32	33	28	5
March 10, 2014	54	41	48	17	28	(11)
March 11, 2014	51	33	42	23	28	(5)
March 12, 2014	34	18	26	39	27	12
March 13, 2014	39	14	27	38	27	11
March 14, 2014	54	38	46	19	27	(8)
March 15, 2014	40	28	34	31	27	4
March 16, 2014	29	19	24	41	26	15
March 17, 2014	39	20	30	35	26	9
March 18, 2014	51	30	41	24	26	(2)
March 19, 2014	47	35	41	24	25	(1)
March 20, 2014	48	31	40	25	25	-
March 21, 2014	58	33	46	19	25	(6)
March 22, 2014	42	29	36	29	24	5
March 23, 2014	30	21	26	39	24	15
March 24, 2014	37	20	29	36	23	13
March 25, 2014	31	21	26	39	23	16
March 26, 2014	39	17	28	37	22	15
March 27, 2014	54	35	45	20	21	(1)
March 28, 2014	55	34	45	20	20	-
March 29, 2014	41	28	35	30	19	11
March 30, 2014	57	25	41	24	18	6
March 31, 2014	68	44	56	9	17	(8)

Month To Date Heating Degree Days

March 31, 2014	997	791	206
----------------	-----	-----	-----

Year To Date Heating Degree Days

March 31, 2014	3,756	2,902	854
----------------	-------	-------	-----

Season To Date Heating Degree Days

March 31, 2014	6,229	4,983	1,246
----------------	-------	-------	-------